





—

ÓP



D/A



“ ” “ ”

/


1


“ ”

2

3







Ctrl+R

E:\ \ \

\

- Ctrl+X
- _____
- ESC _____
- “ ”



“ ”



“ ”



“ ”

“ ↑ ”



“ ”

“ ↓ ”



“ ” “ ”

“ ” “ ”

“ ”

∫ “ ”

“ ”

X

n

“ ”

“ ”

“

”

“

”

“

”

“

”

“

”

’ p

“ ” “ ”

“ ” È•H! % `...i

“ ”

u

“ ” “ ”



1. “ ”

2.

“ ”

“ ” “ ” “

” “ ”

“ ”

“ ” “ √ ”

“ ”

“ ”

“ ”

“ ”

“ ”

“ ” “ ” “ ”

”

“ ”

“ ”

Ä,e[ñ0 RP•'

“ ”

“e[Ÿ P tE &~e[ñE

”

”

“ ”

”

“ ”

“ ”

“ ” “ ”

“ ” “ ” 1.732

“ ” 0° 120° 120°

“ ” 0° 120° 120°

90°

“ ”

“ ”

“ ”

“ ”

“ ” “ ”

“ ”

“ ” “ ”

“ ”

“ ”

“ ”

“ ”

“ ”

1.2



“ ”

ó B

“

”

“

”

“

”

“

“


”

“

”

“

”



66

99




66

99

66

99



设置谐波含量


数据项	谐波名	幅值V	相位°
UA	直流	0.000	0.0
UB	2次	0.000	0.0
UC	3次	0.000	0.0
	4次	0.000	0.0
	5次	0.000	0.0
	6次	0.000	0.0
	7次	0.000	0.000

“ ”

“

"

“√”



2

“ ”

“

"

“ ”

“ ”


IA

“

"


“

"



66

99



66

99 66

99 66


99 66

99 66

99

66

99



99 66

99 66

99

66

99

66

99

66

99

“

”

“

”

“

”



“

”

dv/dt

“


”

dv/dt

“

”







” “ ”

、 、

”

“1/1
、 √ » G 3 4 6 0 2 0 z Z - × + ② 、 8

“ ” “


“ ”


“ ”

“ ” È

8


“+ «
Z z ②
! 1/1 4 1 0
Q 1 5 “ 0 @
“+ «
“+ «







“ ” “ ” “ ”

“ ”



“

”



●


u

☾

ž

BZB \$99.99 100% OFF

“ ”



AN BN CN AB BC CA ABN BCN CAN ABC

Z Φ R X

× “ ” 0.95 1.05
0.8 1.2 “ ”

$$K_o = (Z_0 / Z_1 - 1) / 3$$
$$\Phi(Z_1) \quad \Phi(Z_0) \quad K_o \quad K_{or} \quad K_{ox}$$

$$K_{OX} = (X_0 / X_1 - 1) / 3$$

$$\Phi(Z1) \quad \Phi(Z0)$$

“ ”

p

p

U

I

x “ ”



1..

57.7V

Vf ≤

57.7V

2.

F₂ p

“ ” “ ”
“ ” “ ”

c

π

0

“

”

“

”

“

”

“

Ÿ

Ď

“ ”

K6 ãm." jñ m" , dK x k i . N m " H

c

GPS

ia o 』 j m " ?』

“ ”

“ √ ”

Z- aK q K q

。

E 6 0 K E 』 T ~ ÈpGë ж

“

”

“

”

“

”

“

”

“

”

■

■

66

77

■

■


■

66

77

”

“




PT CT



UX

$$\sqrt{3} \quad \sqrt{3}$$






“ ” “ ” È

“ ”

“

1

“ ”



Z/T

UX

负序定值检验

故障类型	A相接地	
负序电流 $3I_2$ 定值	2.000	A
整定动作时间	1.500	S
试验时间	2.000	S
故障电压	20.000	V
故障电压角	70.0	°

短路电流整定倍数

☒ 0.950 ☒ 1.050

确定 取消

z/t 动作特性

故障类型	A相接地	
短路电流	5.000	A
阻抗角	90.0	°
阻抗变化始值	5.000	Ω
阻抗变化终值	1.000	Ω
阻抗变化步长	0.200	Ω
整定动作时间	0.500	S
试验时间	0.700	S

确定 取消



100V

“

"

“

"

“

"

“

"

“

"

“

"

“

"

“

"

“

"

“

"



66

77

66

77

66

77

66

77

66

77

F

+ | Γ 3B

68

“

”

“

”

“

”

●

●

”

●

“

”

“


”


“

”



●

>





33



66

33



66

33

66

33

66

33

2

66

33

33

66

33

66

33

66

33

66

33

66

33

66

33

66

33

66

33

2

66

33

“ ” “ ”

“ ” “ ”

“ ” “ ”

“ ” “ ”



1. “ ”

IC

IA

IB

2. “ ”

IA IB IC

A B C

la lb



“ ” “ ”




- 1
- 2

Ir Id

- 1
- 2





$$3 \quad Y \quad Y_0 \quad / \quad -1$$

$$\begin{array}{ccccccc}
 Y & & & & & & \\
 & , & & , & & & , \\
 I_A = I_A - I_C & & I_B = I_B - I_A & & I_C = I_C - I_B & & I_a = I_a - I_b \quad I_b = I_b - I_c \quad I_c = I_c - I_a \\
 & & & & & & Y_0 \quad , Y
 \end{array}$$



•

Ie1=Sn/ 1.732 U1n CT1
Ie2=Sn/ 1.732 U2mT

$$I_d = |I_1 + I_2| \quad I_r = \text{Max}\{|I_1| \quad |I_2|\}$$

“ ” “ ”

È

8071.01% × VDB! 6 Q •
Q 3V2

)

À

“ ”

“ ”

“ ”

“ ”

Æ< gJ π π

— ÿ P 06bQ0 0
ø4ë J
ØFO • e Ø ã ØFO
• Q2E ã ã

È

≡
α





1.

“

”

IA

IB

2.

“

”

IA

IB

IC

A

B

C

la


lb

lc

a

b

c



“

”

“

”

“

“

” “

”

”

$\frac{1}{2}D\#(N|E+e^*$

“

”

“ $\frac{1}{2}D\#$ ”

”

“

”

“

”

“

”

“

”

CT

“

”

“

”

B

$\frac{1}{4}$

V



Q

“ ”

“ ” “ ” “ ”

“ ”

“ ” ”

“ ”

“ ”

“ ”

IA

IB

“

“

”

“

”

“

”

“

”

○

○



“ ”

20A

“ ” “ ”

“ ”

“ ”


$$I_{sh} = \frac{4.000}{1.000} A = 4.000 A \quad I_h = \sqrt{6.100} A \quad I_l = \sqrt{1.900} A$$

“ ”

“ ”

“ ”

$$I_{sj.h} = I_h * K_h \quad I_{sj.l} = I_l \quad K_l$$



6-35KV



“ ” “ ”

“ ”

“ ”

电压	
UA	57.735V 0.0°
UB	57.735V 240.0°
UC	57.735V 120.0°

电流	
IA	0.000A 0.0°
IB	0.000A 0.0°
IC	0.000A 0.0°

当前频率

“

”

”

“

参数设置	
试验参数	
故障相	A相
故障电流	7.200 A
故障电压	30.000 V
灵敏角	0.000°
故障前延时	25.000 s
最大故障时间	1.200 s
说明	
开出1接至保护装置的断路器位置 开出2接至保护装置的重合闸位置	
确定	

€

✂

“

”

“

”

“

”

“

”

“

”

“

”

H

“

”

“

”

“

”

df/dt

“

0_{dt} ”

“

“

”

”

“

$\lambda \propto p$

”

%

90

功率方向试验参数

试验相	试验参数
☒ A相	故障前延时 0.500 s
	最大故障时间 0.500 s
☒ B相	试验时间 0.500 s
	90° 接线线电压 50.000 V
☒ C相	试验相电流 5.000 A
	角度分辨率 1.000 °

确定 取消

ANSI/IEEE C37.111-1991COMTRADE

HDR .CFG .DAT

“ ”

.CFG

.CFG .DAT

“ ”

“ ” “ ”

“ ”

“ ”

“


” “ ”

“ ” “ ”


“ \ ”

“ ”

WORD




1



2

3

4



5

1D7 1D8 1D9 1D10

2

J
1

~
DŌJINZOKU




5

φ φ φ φ φ φ


φ

φ



6

102



4

1

“

”

“ ” “ ”

II

II

(2)

(6)

3

(1)

(2)

(4)

đ

Λ 0 4 00

(4)

8# Ô Œ

(5)

5 RCS 900

(1) RCS 900

(2)

RCS 901

“ ”

(12)


RCS 941 / 951


K^upe

”
 1.1 0.9 1.2 10A “
 ”
 • “ ” “ ”
 “ XX ”
 I II III
 • “ ” “ ”
 “ XX ”
 I II III
 • “ ”
 ” “ ”
 3s 5s

• TV TV “TV ”
 “ ”

(2) RCS-978





3

Y/Y

I*

I

1*Ie1

Ie1

Y

150°

“ ”

I

III

1*Ie2



Ie2


I

II

I

3





“

"

“

"

“

"

“

"

“

"

“

"

“

"

“

"

“

"

“

"

“

"

66

"

“

"

“

”

“

”

100

“ ”

“ ”

“ ”

57.735V

I

I

“

”

(4) RCS-915

000 000 iλ

Ä

•

•

u

+ 5